


LEGENDA	
G.U.	GULOVÝ UZÁVER
R	REDUKCIA
CHR	CHRANICKA
--- --	ROZVOD PROPANU 150kPa
<b>HUPB</b>	HLAVNÝ UZÁVER PLYNU BUDOVY G.U.DN32
<b>1</b>	PLYNOVÝ INFERAŽIARIČ BEZ ODVODU SPALIN ALKE BV globol-5 13P 5,6kW 0,4 kg/hod 6ks

<div><div><div>ZABOKREKY 127, 038 40</div><div>mobili: 0915987559</div><div>e-mail: energetech.marko@gmail.com</div><div>IČO: 43294642 DIČ: 1046241427</div></div></div>					AUTOR		PROJEKTANT	ZODP. PROJEKTANT	VYPRACOVAL:
AUTHOR		CHIEF DESIGNER	EXECUTIVE DESIGNER	ELABORATED					
Milan MARKO		Ingarch V. HLADKÝ	Emil MAŽGUT	Milan MARKO					
STAVEBNÍK PRO-HOUSE-OWNER									
MORKY PETRÁNEK s.r.o., ČEREMOŠNÉ 135, 039 01 TURČ. TEPLICE									
MÍSTO PLACE		k.ú. Čeremošné parc.č. 167/4,5; 168, 169, 170, 171/1 - 14							
NÁZOV STAVBY		HOSPODÁRSKY DVOR, ČEREMOŠNÉ							
BUILDING NAME		ROZŠÍRENIE PREVÁDZKOVÝCH PRIESTOROV							
OBSAH CONTENTS		SCHEMA ROZVODU PROPANU							
ČASŤ PART		SO 03 ROZVOD PROPANU							
		STUPEŇ DEGREE		PD PRE POVOLENIE	SADA				
PROFESIA		PLYNOINŠTALÁCIA							
DÁTUM		07/2013							
ČÍS.ZAKAZKY		01-07-2013							
FORMÁT		3-A4							
VÝKRES		04							
		MIERKA							